



City of Hanford Fire Department

Fire Prevention and Community Risk Reduction Division

Fire Marshal

Nikkie Chamberland



Tent & Membrane Structure Checklist

Any tent or membrane structure over 400 sqft. (or canopy over 700 sqft.) *shall* have the following items in place:

- A 2A:10B-C fire extinguisher shall be provided, (75' on center) and have a current service tag.
- Each structure shall have a permanently attached OSFM tag.
- The means of egress shall be maintained, *and illuminated*, while the tent is occupied.
- "No Smoking" signs shall be located in a conspicuous place.
- Flammable liquid-fueled (LPG) appliances shall not be used inside a tent.
- Motor vehicles for display shall have the battery disconnected, and contain no more than 5 gallons of fuel.
- No combustible vegetation shall be displayed inside a tent.
- All temporary electrical services, and generators, must be properly grounded.

Temporary Food Vendor Checklist

All temporary food vendors shall comply with the following requirements:

- A 2A:10B-C fire extinguisher shall be inside the booth and have a current service tag.
- All grease-laden cooking operations shall be conducted outside or under an approved hood with a suppression system.

A Class "K" Fire extinguisher shall be provided outside for grease-laden cooking operations.

All temporary wiring shall be free from damage.

The means of egress shall be maintained clear.

To request this brochure in an alternative format, please call 559-585-2594. The City of Hanford prohibits discrimination based on race, color, or national origin in programs, services, and activities.